

**CORRIGENDUM-I**

**August 17, 2016**


**Ref. Tender No. BGL/323/2016-17, Dated: 08.08.2016**

**Sub: Procurement of 12 Nos of CNG CAR Dispensers for BGL Hyderabad, Vijayawada and Kakinada.**


**This is for general information to all bidders that following details enclosed herewith shall form part of the bidding documents.**

**This is for general information to all bidders:**

Sr No	Section	Bid Document Description	Bidders Queries	BGL Repsonse
<b>Commercial Query</b>				
1	Volume -I of II , page no 2 of 155	Bid Security :	Bidder requested for exemption of Bid Securing since bidder is registered under Single Point Registration Scheme of NSIC and we eligible to get the benefits under "Public Procurement Policy for Micro & Small Enterprises (MSEs) Order 2012"	Tender Condition prevails. NSIC/ MSME Registration certificates is not accepted for exemption of EMD amount.
<b>Technical Queries</b>				
1	Vol II of II, Section - 9, Technical Specification, Page NO. 90 of 100	Annexure-I: Approved Vendor List	BGL has asked for Swagelok/ Parker make fittings. Request to add Hyllok & Dk-lok fittings be included as these are used by many CGD companies in India like Gujarat Gas, Gail Gas, MNGL etc.	Bidder to submit the necessary documents supporting documents as per Clause no: 1,2,3 of Page 91 of 100 of vol II of II of Bid Document.



Sr No	Section	Bid Document Description	Bidders Queries	BGL Reponse
2	Vol II of II, Section - 9, Technical Specification, Page No. 66 OF 100.	Inspection & Testing	BGL has asked for RT certificates for valves. Hydrostatic test certificates can be provided for the valves.	RT certificates required if valves are made of welded assembly. Hydrostatic certificates are acceptable for the control/safety valves for forged made.
3	Vol II of II, Section - 9, Technical Specification, Page No. 90 of 100	Annexure-I: Approved Vendor List	BGL has asked for Staubli/Parker breakaway couplings. Bidder Requested to add OPW and Weh breakaway couplings be included in the list as these are used by major CGD companies in India.	OPW and Weh are acceptable
4	Vol II of II, Section - 9, Technical Specification, Page No. 38 OF 75	Scope of Supply for CAR Dispensers, Clause: 9.1.15	Coalescent and particulate filter to be provided at inlet of each bank supply line with manual drain valve to ensure that the oil carryover in the CNG being filled to vehicle is < 5 ppm and particulate size is < 2 Micron-. Bidder requested that PARTICULATE FILTER TO BE OF 3μ TO 6μ.	Tender Condition prevails.
5	Vol II of II, Section - 9, Technical Specification, Page No. 90 of 100	Annexure-I: Approved Vendor List	The tubing shall be of Sandvik / FAE make-Parker comments. Bidder requested to include Parker as Vendor for Tubing.	Bidder to submit the necessary documents supporting documents as per Clause no:1,2,3 of Page 91 of 100 of vol II of II of Bid Document.
6	Vol II of II, Section - 9, Technical Specification, Page No. 88 of 100	Annexure-I: Approved Vendor List	Emerson Process Management (Micromotion) - CNG 050 with 2700 transmitter-Parker comments: Bidder requested to include Endress + Hauser as a vendor for Mass Flow Meter.	Tender Condition Prevails.



Sr No	Section	Bid Document Description	Bidders Queries	BGL Repsonse
7	Vol II of II, Section - 9, Technical Specification, Page No. 89 of 100	Annexure-I: Approved Vendor List	Parker as a vendor not Included in Vendor List- Parker Comments: Bidder requested you to include Parker as Vendor for Pressure Control Valve	Bidder to submit the necessary documents supporting documents as per Clause no: 1, 2, 3 of Page 91 of 100 of Vol II of II of Bid Document.
8	Vol II of II, Section - 9, Technical Specification, Page No. 90 of 100	Annexure-I: Approved Vendor List	Parker as a vendor not Included in Vendor List- Parker Comments: Bidder requested to include Parker as Vendor for Pressure Regulators	Bidder to submit the necessary documents supporting documents as per Clause no: 1,2,3 of Page 91 of 100 of Vol II of II of Bid Document.

**Bidder shall take in to account the above while submitting their bid.**

**The Corrigendum – I shall form the integral part of the tender document.**

**All other Terms and Conditions of the tender document shall remain unaltered.**

**M/s. Bhagyanagar Gas Limited**

**Bonny K Joseph**  
**Dy. Manager (C&P)**

