

CORRIGENDUM-III

14 October, 2016

Ref. Tender No. BGL/327/2016-17 dtd 21.09.2016

Sub: Tender for Rate Contract for Mechanical & Electrical works for construction of CNG DBS & Online Stations in Hyderabad, Vijayawada & Kakinada.

This is for general information to all bidders that following details enclosed herewith shall form part of the bidding documents.

This is for general information to all bidders:

Sr No	Section	Bid Document Description	Bidders Queries	BGL Repsonses
General				
1	Vol I of II, (Page 2 of 115)	Due Date & Time of submission of bid.		Due Date & Time of submission of bid extended till 21.10.2016 at 1500 hrs. (IST)
Technical Query				
2	Vol II of II,Section-9 SOR (Page 47 of 66)	SOR item no:1.b.i)	3.5CoreX120Sq. mm Armoured copper not available in the market	To be read as 3.5 Core x 120 Sq.mm Armoured Aluminium
4	Vol II of II,Section-9 SOR (Page 47 of 66)	SOR item no:1.b.ix)	Type of cable not mentioned except size	Single core flexible Copper cable of size as mentioned in SOR item.
8	Vol II of II,Section-9 SOR (Page 49 of 66)	SOR item nos:11	Thickness of Pipe not mentioned	PVC pipe to be used for cable conduiting shall be suitable for 4Kg/cm2 as per standard practise of Electrical cable laying

Bidder shall take in to account the above while submitting their bid.

The Corrigendum – III shall form the integral part of the tender document.

All other Terms and Conditions of the tender document shall remain unaltered.

For and on Behalf of
M/s. Bhagyanagar Gas Limited


Bonny K Joseph
Dy. Manager (C&P)

