



Sr No	Section	Bid Document Clause	Bidders Queries	BGL Repsonse
	Vol II of II, Section - 7, Technical Specification, Page No. 4 of 31		Bidder requested to confirm length and size details for Power Cable.	Cable shall be provided from Distribution Panel board to VFD and from VFD to Compressor Panel. Size of cable-4Corex70Sq.mm Armoured Copper and its length shall be approximately 25mtrs.
			Bidder requested to distance between Motor and VFD.	Distance between Motor and VFD shall be 35 mtrs (approx.)
			Bidder requested to confirm PC/laptop is in bidder scope or not.	PC/laptop is in the scope of bidder.

**Bidder shall take in to account the above while submitting their bid.**

**The Corrigendum – I shall form the integral part of the tender document.**

**All other Terms and Conditions of the tender document shall remain unaltered.**

**M/s. Bhagyanagar Gas Limited**

**Bonny K Joseph**

**Dy. Manager (C&P)**

*(Signature)*  
 11/11/17  
 Bhagyanagar Gas Limited,  
 1st Floor,  
 2nd Cross, 1st Stage, 1st Block, 1st Phase,  
 Bangalore - 560 004.