

CORRIGENDUM#1**TO****BIDDING DOCUMENT**

BIDDING DOCUMENT NO. : MEC/23R8/01/51/D2/T03/ER/6510

SUBJECT OF BIDDING DOCUMENT : LAYING OF UNDER GROUND PE PIPE LINES AND ABOVEGROUND GI INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY AT CONSUMER END AT HYDERABAD

The terms and conditions of the Bidding Document stands modified to the extent indicated below and all other terms and conditions of the Bidding Document remains unaltered:

Sn. No.	PART of Bidding Document	Section	Page No.	Clause No.	Clause Description	Additions / Deletions / Modifications
1.	PART-III	SECTION 4.1	31 of 32	19	Appendix To Particulars of Job Specifications- List of Approved Suppliers for Bought out Items	GI fittings: 1. M/s Jinan Meide Casting Co. Ltd., Japan stands added as approved Supplier for GI Fittings. 2. M/s Ningbo Huaping Metal work Co. Ltd., China stands added as approved vendor for GI fittings.
2.	PART-III	SECTION 4.1	31 of 32	19		Isolation Valves & Appliance Valves: 1. M/s. Zhejiang Valogin Technology Co. Ltd., China stands added as approved vendor for Isolation Valves & Appliance Valves. 2. M/s Ningbo Huaping Metal work Co. Ltd., China stands added as approved vendor for Isolation Valves & Appliance Valves.

Sn. No.	PART of Bidding Document	Section	Page No.	Clause No.	Clause Description	Additions / Deletions / Modifications
3.	PART-III	SECTION 5 - Schedule of Rates (SOR)	6 of 10	-	<p>Installation of heavy duty GI pipes (as per IS:1239) at all floors along with supply and installation of all required fittings (approved make) such as sockets, elbow, tee, reducer, bend, union, GI plug, endcap etc, fixed vertically as well as horizontally for providing PNG connection to house hold in various type of Buildings including Highrise buildings. The scope also includes supply and installation of TF, wherever required. Item includes pneumatic testing of the assembled section as per the specification and standard procedure of testing of the complete installation, making required arrangement for fixing of the pipes such as scaffolding, rope ladder etc, supply and fixing of approved clamp, screw (SS screw of approved make), dowel plug, steel supports with rods, fasteners etc. If required, making holes by core cutting etc and making good the holes with grout of the matching colour/shade also included. All threading shall be NPT threading with thread making machine. Only GI Pipes are Free issue material. All of the assembled section as per the specification and standard procedure of test</p>	<p>Installation of heavy duty GI pipes (as per IS:1239) at all floors along with supply and installation of all required fittings (approved make) such as sockets, elbow, tee, reducer, bend, union, GI plug, end cap etc, fixed vertically as well as horizontally for providing PNG connection to house hold in various type of Buildings including High rise buildings. The scope also includes supply and installation of TF, wherever required. Item includes pneumatic testing of the assembled section as per the specification and standard procedure of testing of the complete installation, making required arrangement for fixing of the pipes such as scaffolding, rope ladder etc, supply and fixing of approved clamp, screw (SS screw of approved make), dowel plug, steel supports with rods, fasteners etc. If required, making holes by core cutting etc and making good the holes with grout of the matching colour/shade also included. All threading shall be NPT threading with thread making machine. Only GI Pipes are Free issue material. All GI pipe fittings and clamps, shall be powder coated of approved colour and shade.</p>

Note: This Corrigendum shall form an integral part of the bidding document and shall be signed/stamped and submitted along with the bid.

(STAMP & SIGNATURE OF BIDDER)