



CORRIGENDUM #1
for
**LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI
INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY
AT CONSUMER END AT HYDERABAD**
for
CITY GAS DISTRIBUTION PROJECT
Bid Document No. MEC/23R8/01/51/S2/PE/00/0002

Date: 31.08.2016

**Owner: M/s BHAGYANAGAR
GAS LIMITED**

| Sl. No. | Description | Volume | Tender Page No. | Clause / Para / Section | Amendment / Addition / Modification / Deletion | |
|---------|---|-----------|---------------------------|-------------------------|--|---|
| 1 | APPENDIX –I to Particular Job Specification | I OF III | Page no. 313 & 314 of 315 | Clause No. 19.0 of PJS | Addition | <p><u>Isolation Valves & Appliance Valves</u></p> <p>1. M/s Zhejiang Valogin Technology Co. Ltd., China stands added as approved vendor for Isolation Valves & Appliance Valves.</p> <p>2. M/s Ningbo Huaping Metal Work Co. Ltd., China stands added as approved vendor for Isolation Valves & Appliance Valves.</p> <p><u>GI Fittings</u></p> <p>1. M/s Jinan Meide Casting Co. Ltd., Japan stands added as approved vendor for GI Fittings.</p> <p>2. M/s Ningbo Huaping Metal Work Co. Ltd., China stands added as approved vendor for GI fittings.</p> |
| 2 | Scope of work - Installation of above ground GI pipes | II OF III | Page no. 32 of 181 | Clause No 2.6 | Addition | <p>In confined areas, particularly in Basements in case of Multi-storeyed / High rise Apartments, GI piping has to be laid laterally with Welded Joints per T4S Specifications.</p> |





CORRIGENDUM #1
for
LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI
INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY
AT CONSUMER END AT HYDERABAD
for
CITY GAS DISTRIBUTION PROJECT
Bid Document No. MEC/23R8/01/51/S2/PE/00/0002

Date: 31.08.2016

**Owner: M/s BHAGYANAGAR
 GAS LIMITED**

| Sl. No. | Description | Volume | Tender Page No. | Clause / Para / Section | Amendment / Addition / Modification / Deletion | |
|---------|--|----------|---------------------|-------------------------|--|---|
| 3 | Installation of Riser and Lateral Pipes in High Rise Building for PNG connection | I OF III | Page no. 296 of 315 | Clause no 3.2.2.11 | Addition | In confined areas, particularly in Basements in case of Multi-storeyed / High rise Apartments, GI piping has to be laid laterally with Welded Joints per T4S Specifications. |
| 4 | BID EVALUATION CRITERIA (BEC) - Financial Criteria | I OF III | Page no. 8 of 315 | Clause No. 5.2.4 of IFB | Amendment | In case the audited financial result of 2015-16 is not available, then the bidder has an option to submit their audited financial results of 2012-13, 2013-14 & 2014-15 for annual turnover and 2014-15 for Working Capital & Net Worth. The same will be considered. |



| | | |
|---|--|--|
|  Bhagyanagar Gas Ltd. | BHAGYANAGAR GAS LIMITED CITY GAS DISTRIBUTION PROJECT AT BENGALURU LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY AT CONSUMER END AT HYDERABAD |  मेकॉन ISO 9001 Company |
|---|--|--|

BID DOCUMENT NO. MEC/23R8/01/51/S2/PE/00/0002

PRE-BID MEETING HELD AT BHAGYANAGAR GAS LIMITED, HYDERABAD ON 11.08.2016 AT 10.30 HRS

CLARIFICATIONS TO PRE-BID QUERIES GIVEN BY BGL / MECON

| SL. No. | Clause No. as per Tender | Bidders Query / Clarification | BGL/ MECON's CLARIFICATIONS |
|---------|--------------------------|--|--|
| 1) | General | <p>Scope of supply - Isolation valve & appliance valve are not mentioned in scope of supply. Supply & installation of isolation valve is in Item No - 12 in SOR but there is no where mentioned about appliance valve.</p> | <p>Supply of Isolation valves, appliance valves & flexible hose are in the scope of supply of the contract.</p> <p>Please refer clause no 3.1 of Vol I of III (Page No 5 OF 315) which states that only MDPE & GI pipes of various sizes along with Meters and Regulators shall be free supply to the contractor. Supply and installation of Copper service pipes, isolation and appliance valve etc. is also mentioned in the same clause.</p> <p>Clause No 1.2 (Scope of work) of PJS (Page No. 290 of 315) also states that isolation valve & appliance valve are in the scope of supply of contract.</p> <p>Please refer Item No. 8 (8.1, 8.2 & 8.3) in SOR, where supply of appliance valve is included in scope of supply.</p> |



| | | |
|---|--|--|
|  Bhagyanagar Gas Ltd. | BHAGYANAGAR GAS LIMITED CITY GAS DISTRIBUTION PROJECT AT BENGALURU LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY AT CONSUMER END AT HYDERABAD |  मेकॉन ISO 9001 Company |
|---|--|--|

BID DOCUMENT NO. MEC/23R8/01/51/S2/PE/00/0002

PRE-BID MEETING HELD AT BHAGYANAGAR GAS LIMITED, HYDERABAD ON 11.08.2016 AT 10.30 HRS

CLARIFICATIONS TO PRE-BID QUERIES GIVEN BY BGL / MECON

| SL. No. | Clause No. as per Tender | Bidders Query / Clarification | BGL/ MECON's CLARIFICATIONS |
|---------|--------------------------|---|--|
| 2) | General | Item No. 11 in SOR:- GI pipes to be installed welded / threaded not mentioned. | GI pipes installation is generally NPT threaded (please refer tender document) and welded in confined areas like basement Kindly refer Clause No 2.6 (Page No 32 of 181) of Volume II for installation of GI pipes and clause no 3.2.2.11 (Page No 296 of 315) of Volume I for installation of Riser and Lateral Pipes in High Rise Building and corrigendum 1 . |
| 3) | General | Valve chamber is to be made of bricks and are of two sizes Type 1 - 1000 X 1000 mm for 90 & 125 mm pipe Type 2 - 600 x 600 mm for 63 mm & below | Tender conditions prevail. Kindly refer Drawing No MEC/23R8/01/S3/D2/CF/00/9003/R0 for Type I (90 mm & 125mm NB valves) and MEC/23R8/01/S3/D2/CF/00/9004/R0 for Type II (63 mm & 32 mm NB valves) of Volume III for valve chamber sizes and other details. |
| 4) | General | Size of route marker will be 750 x 250 mm. | Tender conditions prevail. Kindly refer Drawing No. MEC/23R8/01/S3/D2/CF/00/9005/R0 of Volume III for size of Route Marker. |



| | | |
|---|--|--|
|  Bhagyanagar Gas Ltd. | BHAGYANAGAR GAS LIMITED CITY GAS DISTRIBUTION PROJECT AT BENGALURU LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY AT CONSUMER END AT HYDERABAD |  मेकॉन ISO 9001 Company |
|---|--|--|

BID DOCUMENT NO. MEC/23R8/01/51/S2/PE/00/0002

PRE-BID MEETING HELD AT BHAGYANAGAR GAS LIMITED, HYDERABAD ON 11.08.2016 AT 10.30 HRS

CLARIFICATIONS TO PRE-BID QUERIES GIVEN BY BGL / MECON

| SL. No. | Clause No. as per Tender | Bidders Query / Clarification | BGL/ MECON's CLARIFICATIONS |
|---------|---|---|---|
| 5) | Bid Evaluation Criteria (BEC) - Technical Criteria Clause no. 5.1.1 of IFB | <p>Bidder should have completed the works for laying of MDPE & GI/Cu pipe Installation for domestic PNG of a value exceeding Rs.177 Lakhs in single contract during last 7 years.</p> <p>Confirm that no. of Purchase Orders/Service Orders under single contract is eligible to meet the BEC Technical Requirements.</p> | Different suborders under a Single Contract meeting the requirement as specified vide clause no. 5.1.1 of IFB will be considered. |
| 6) | Earnest Money Deposit & Contract Performance Bank Guarantee Clause no. 37.1 of ITB | <p>Bid Security BG shall be extended 3 months beyond the DLP of the Contract.</p> <p>When DLP is applicable for 12 months from the date of Completion of the Project Activity then what is the need to extend the Bid Security period 3 months beyond the DLP.</p> | Tender Conditions prevail. |



| | | |
|---|--|--|
|  Bhagyanagar Gas Ltd. | BHAGYANAGAR GAS LIMITED CITY GAS DISTRIBUTION PROJECT AT BENGALURU LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY AT CONSUMER END AT HYDERABAD |  मेकॉन ISO 9001 Company |
|---|--|--|

BID DOCUMENT NO. MEC/23R8/01/51/S2/PE/00/0002

PRE-BID MEETING HELD AT BHAGYANAGAR GAS LIMITED, HYDERABAD ON 11.08.2016 AT 10.30 HRS

CLARIFICATIONS TO PRE-BID QUERIES GIVEN BY BGL / MECON

| SL. No. | Clause No. as per Tender | Bidders Query / Clarification | BGL/ MECON's CLARIFICATIONS |
|---------|---|--|--|
| 7) | Contractors Performance Security Clause no. 24.1 of GCC | Contractor shall furnish 10% of the contract value awarded. As per ITB under clause no.37, it is mentioned that 8% of the Total Individual Order, So clarify. | Refer clause no.8.0 of SCC (Vol. I of III). |
| 8) | Sales Tax/ Turnover Tax Clause no. 99.1 of GCC | Tenderer should quote the price inclusive of all Taxes. What percentage of WCT will be deducted at source against the Cenvatable Invoice. | The prices quoted by the bidders are to be inclusive of all applicable taxes & duties. However, all statutory deductions will be made by the owner as per rules and regulations in force. |
| 9) | Volume I, Annexure 5 to SCC, Clause no. 1 (Terms of payment), Sl. No. 1, (Page no 273 of 315) | SL No. 1. PE PIPELINE laying (For SOR item 1.1, 1.2, 1.3, 1.4) 10% of SOR amount will be paid on submission of all documents for closure of contract. Closure of contract means the individual order or total closure of the contract. Pl confirm. | Closure of contract means closure of the individual release orders that will be issued. |



| | | |
|---|--|--|
|  Bhagyanagar Gas Ltd. | BHAGYANAGAR GAS LIMITED CITY GAS DISTRIBUTION PROJECT AT BENGALURU LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY AT CONSUMER END AT HYDERABAD |  मेकॉन ISO 9001 Company |
|---|--|--|

BID DOCUMENT NO. MEC/23R8/01/51/S2/PE/00/0002

PRE-BID MEETING HELD AT BHAGYANAGAR GAS LIMITED, HYDERABAD ON 11.08.2016 AT 10.30 HRS

CLARIFICATIONS TO PRE-BID QUERIES GIVEN BY BGL / MECON

| SL. No. | Clause No. as per Tender | Bidders Query / Clarification | BGL/ MECON's CLARIFICATIONS |
|---------|--|--|-----------------------------|
| 10) | Volume I, Annexure 5 to SCC, Clause no. 1(Terms of payment), SI No. 9, (Page no 274 of 315) | <p>SL No. 9. PNG Connection to Domestic, commercial & industrial Consumers (SOR Item no. 8.0) 70% of SOR amount will be paid on installation of Riser, piping, valves, Regulator & Meter</p> <p>Installation of Riser will be installed upto MCV 1 for all residents & Tapping, Valves, Meter, Regulator etc will be installed only after registration, Full payment for PNG amount and availability of Gas. So Modify the 70% payment for riser installation with MCV 1 only.</p> | Tender conditions prevail. |
| 11) | Volume I, Annexure 5 to SCC, Clause no. 1(Terms of payment), SI No. 1 to 11, (Page no 273 to 275 of 315) | <p>For all SOR items - 10% of SOR amount will be paid on submission of all documents for closure of contract.</p> <p>In case of network not commissioned due to non availability of permission, Gas or any other reasons which are not related to contractor - whether the amount will be paid totally or not.</p> | Tender conditions prevail. |

| | | |
|---|---|---|
|  <p>Bhagyanagar Gas Ltd.</p> | <p>BHAGYANAGAR GAS LIMITED</p> <p>CITY GAS DISTRIBUTION PROJECT AT BENGALURU</p> <p>LAYING OF UNDERGROUND PE PIPELINES AND ABOVE GROUND GI</p> <p>INSTALLATIONS INCLUDING LAST MILE CONNECTIVITY</p> <p>AT CONSUMER END AT HYDERABAD</p> |  |
|---|---|---|

BID DOCUMENT NO. MEC/23R8/01/51/S2/PE/00/0002

PRE-BID MEETING HELD AT BHAGYANAGAR GAS LIMITED, HYDERABAD ON 11.08.2016 AT 10.30 HRS

CLARIFICATIONS TO PRE-BID QUERIES GIVEN BY BGL / MECON

| SL. No. | Clause No. as per Tender | Bidders Query / Clarification | BGL/ MECON's CLARIFICATIONS |
|----------------|---------------------------------|--|---|
| 12) | Time Extension | To extend the Bid submission date for another 10 days instead of 07.09.2016. | Tender conditions prevail. |
| 13) | General | Corrigendum | Corrigendum #1 dated 31.08.2016 has been issued. |
| 14) | General | -- | The Pre-bid Queries & Replies and Corrigendum #1, thus issued shall form part of the Tender Document and shall be taken care of before submission of the bid. |