

CORRIGENDUM - 2

Notice Inviting Tender for “Laying & construction of 12”, 6” & 4” NB Underground Steel pipeline network & Associated works at Hyderabad for City gas distribution project at Hyderabad” - **Bid Document No.: MEC/23R8/01/51/S2/ST/00/0001**

The following clarifications shall form part of the tender:

Sl.No.	Bidder Query	MECON Reply
1.	Kindly confirm the minimum width of the ROU.	As per tender
2.	We understand that necessary permission required for the entire ROU including railway crossings shall be provided by BGL /MECON at the time of starting of work by the contractor. Please confirm.	Please refer clause no. 3.2.1.2 (Statutory Approvals) in PJS – Sec V of Vol-I of tender for scope of liasioning.
3.	We understand that the entire pipe line has to be laid in the land belongs to Government agencies only and no private land is envisaged. Incase, if it is private land, necessary compensation shall be paid to the owner of the land by BGL/MECON and necessary permission shall be given to contractor by BGL/MECON. Kindly confirm.	Confirmed
4.	We understand that the proposed pipe line is not piggable. Please confirm.	The pipeline shall be constructed with 3d bends and barred tees so that cleaning can be carried out in segments by pigging.
5.	We understand that the Radiography shall be taken using external camera unit and not by crawler camera. Please confirm.	As per site conditions.
6.	We understand that commissioning of pipeline shall be carried out segment wise in phases. In such case, once the total line is made ready,	As per tender.

	Contractor need not do once again commissioning of total line. Please confirm.	
7	We understand that inspection of work shall be done by MECON/ BGL. Please confirm.	As per tender conditions.
8.	Ref: Sl.no. 3.2.2.17.3 Crossing by Horizontal Directional drilling (HDD)– Last para at page 15 of 107 of PJS-Sec-V of Vol-I, it is mentioned that Contractor shall deploy only BGL / MECON approved HDD agency. Request you to kindly provide the name of the approved HDD agency so as to quote competitive price.	For makes / agencies not specified in the tender, successful bidder to submit the credentials of makes / agencies and obtain the approval of BGL / MECON.
9.	<u>Other work:</u> Ref:Sl.no.3.2.3.7, Page no. 20 of 107 of PJS-Sec-V of Vol-I, third point which states that provision is to be kept in the terminal for installation of permanent Cathodic system. This is not clear as the contractor scope of work is provision of temporary Cathodic system. Please Clarify & confirm.	The TCP shall be installed such that the terminal boxes / thermit welding done / other facilities shall be usable when PCP is installed in future through impressed current system.
10.	<u>Above Ground Piping work</u> Ref: 4.4.1.11, Page 25 of 107, PJS, Sec-V of Vol-I says that environment for Above Ground Piping shall be normal corrosive where as 4.4.2.5, Page 27 of 107- PJS –Sec –V of Vol-I says that primer and paint suitable for normal corrosive environment. Please clarify which one is to be followed.	The details as provided in clause no. 4.4.1.11 shall be followed.